



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/ 866

Dated: 08 / 08 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the St. Lawrence Public Sr. Sec. School located at A-K Facility Center, Opp.-LIC Colony, Dilshad Garden, Delhi-110095, building comprised of Basement, Ground, First floor & Temporary rooms on Terrace (Second Floor) but school is running on Basement, Ground and First Floor only, owned / occupied by St. Lawrence Public Sr. Sec. School, was issued PSC vide letter No. F6/DFS/MS/School/2018/1119 Dated 17/05/18. The School building was re-inspected by the officer concerned of this department on 03/08/2022 in presence of Mrs. Shelly Sehgal and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E. Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 08 / 08 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 08 / 8 / 2022 at New Delhi by.



  
(S.K. DUA)  
**DY. CHIEF FIRE OFFICER.**

Copy to :-

1. The Principal, St. Lawrence Public Sr. Sec. School, A-K Facility Center, Opp.-LIC Colony, Dilshad Garden, Delhi-110095.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. Basement shall be used strictly as per Building By-Laws.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.DelhiGovt.nic.in](http://WWW.dfs.DelhiGovt.nic.in).

  
VICE PRINCIPAL  
St. Lawrence Public Sr. Sec. School  
A-K, Facility  
Dilshad Garden  
Delhi-110095  
  
VICE PRINCIPAL  
St. Lawrence Public Sr. Sec. School  
A-K, Facility  
Dilshad Garden  
Delhi-110095